



MEG ENERGY

**CHRISTINA LAKE REGIONAL PROJECT
Phase 3A EPC for Central Plant Facilities**

SLI Project No. 511036



SNC-LAVALIN



SNC-LAVALIN

Vendor's drawing review for conformity with specifications and design drawing.

This review does not relieve the vendor of his responsibility for errors in design and detailing as detailed in his contract.

- A1 Not suitable to initiate fabrication. modify as noted, resubmit for review
- B1 Suitable to initiate fabrication as noted. modify as noted, resubmit for review
- C1 Suitable to fabricate to completion as noted. submit final documents including as-builts as required
- D1 Suitable to fabricate to completion. submit final documents including as-built documents as required
- E1 Not suitable as final documents as noted. modify as noted and resubmit.
- F1 Suitable as final documents. no further resubmittal required (unless revised by vendor)
- VX Vendor document cancelled.

Vendor: Sewon Cellontech Co. Ltd. - P00007

No.:D0644-COM-P-58

Rev: 1

Doc.
Title:

D00.01 - COMPLETED BUYER'S EQUIPMENT DATA SHEET - Tag: 3A-V-574

Client Code:

Project No: **511036**

Date Rec'd: 2014/11/10

Reviewed by: **C.Simons**
Date: **08 December 2014**

Document No:
P-5120-01-0140

Submittal:
02

 SEWON CELLONTECH	DOCUMENT FOR EQUIPMENT	SWC JOB NO	D-0644
		ITEM NO.	3A-V-574
		SWC DOC. NO.	D0644 -COM-P-58

 MEG Energy Corp.		 SNC-LAVALIN	
P.O NO.	P-5120-01		
PROJECT NAME	CHRISTINA LAKE REGIONAL		
PROJECT NO.	508298		
DOCUMENT TITLE	Completed Buyer's Equipment Data Sheet		
CODE	D00.01		
ITEM NO.	ITEM DESCRIPTION		
3A-V-574	Dry Instrument Air Receiver		

FOR APPROVAL



- Total Sheet : 4 Sheet (Including This Cover)

1	<i>G.S.GIM 10/29/14</i>	<i>X</i>	<i>FOR HHCHO 10/29/14</i>	SECOND ISSUE
0	G.S.GIM	B.J.KIM	H.H.CHO	FIRST ISSUE
REV.	PREPARED BY	REVIEWED BY	APPROVED BY	DESCRIPTION


SEWON CELLONTECH CO.,LTD.

PRESSURE VESSEL DATA SHEET				Data Sheet No.: DS-CL03A-C-500-V574			
Specification No.: 085354-3010-PV-10			Requisition No.: 508298-000-45-MR-5120-0001				
DESIGN DATA			PAINTING & INSULATION				
Service <u>Dry Instrument Air Receiver</u> Operating Temperature <u>43.0 °C</u> Pressure <u>865.0 kPag</u> Design Temp. Min.: <u>2</u> <u>-29.0 °C</u> Max.: <u>80.0 °C</u> Design Pressure @ Minimum Temperature: <u>1034.0 kPag</u> @ Maximum Temperature: <u>1034.0 kPag</u> Sour Service <u>No</u> Lethal Service <u>No</u> New Vessel MAWP Limited by <u>BTM HEAD</u> @ <u>1054 kPag</u> Corrosion Allowance - Shell / Heads <u>1.6 / 1.6 mm</u> Wall Thickness - Shell / Heads <u>2</u> <u>17 / 1.0</u> / <u>2</u> <u>17(Hm) / 1.0 mm</u> Joint Efficiency - Shell / Heads <u>1.0 / 1.0</u> Registration <u>Alberta</u> Design Code <u>ASME Sec VIII D1</u> Code Stamp <u>Yes, U Stamp</u> Orientation <u>Vertical</u> Post Weld Heat Treatment <u>Per Code</u> Head Type <u>2:1 Semi-elliptical with 50 mm SF</u> Allowable Stress @ Design Temperature <u>Per Code</u> kPa Ambient Temperature <u>2</u> <u>10 °C</u> Max Wind Speed <u>31.4 m/s</u> Minimum Metal Design Temperature <u>2</u> <u>-29 °C</u> Fluid <u>Dry Air</u> Fluid Density <u>991 (Liquid) kg/m³</u>			External Surface Preparation <u>Per Spec 085354-3010-PC-50 Table 3, System A1</u> Internal Surface Preparation <u>N/A</u> <u>2</u> Structural Surface Preparation <u>N/A</u> Vessel External Prime <u>Per Spec 085354-3010-PC-50 Table 3, System A1</u> Vessel Internal Prime <u>N/A</u> <u>2</u> Structural Prime <u>N/A</u> Vessel External Finish <u>Per Spec 085354-3010-PC-50 Table 3, System A1</u> Vessel Internal Finish <u>N/A</u> <u>2</u> Structural Finish <u>N/A</u> External Insulation - Shell <u>N/A</u> <u>2</u> External Insulation - Heads <u>N/A</u> <u>2</u> Internal Insulation <u>N/A</u> External Cladding <u>N/A</u> <u>2</u> Insulation - Bottom Head <u>N/A</u> <u>2</u> Insulation - Skirt <u>N/A</u> Fireproofing - Skirt <u>N/A</u> Fireproofing - Saddles <u>N/A</u>				
MATERIALS			QUALITY CONTROL / INSPECTION / TESTING				
Shell <u>SA516 Gr 70N</u> Repads <u>SA516 Gr 70N</u> Heads <u>SA516 Gr 70N</u> Fittings <u>2</u> <u>SA234 WPB</u> Trays <u>N/A</u> Supports <u>SA516 Gr 70N</u> Bolts/Nuts <u>SA193 B7/SA194 2H</u> Flanges <u>2</u> <u>SA105N</u> Nozzle-Necks <u>2</u> <u>SA106 Gr B</u> Gaskets <u>2</u> <u>SPW SS 316</u> Internal Lining <u>N/A</u> Pipe <u>2</u> <u>SA106 Gr B</u> Internals <u>N/A</u> Mist Eliminator <u>N/A</u> Structural Attachments - External <u>SA516 Gr 70N</u> Structural Attachments - Internal <u>SA516 Gr 70N</u> Material Impact Test Required <u>Per Code</u> Certified Elevated Temp Tests Req'd <u>No</u>			Hydrotest Pressure <u>Per Code</u> kPag Hydrotest Medium <u>Water</u> Hydrotest Duration <u>Min 1</u> hrs Radiographic Inspection <u>RTI</u> <u>2</u> Ultrasonic Inspection <u>Per Spec 085354-3010-PV-10</u> <u>2</u> Magnetic Particle Inspection <u>Per Spec 085354-3010-PV-10</u> Dye Penetrant Inspection <u>Per Spec 085354-3010-PV-10</u> <u>2</u> Material Mill Test Reports <u>Per MR, Section III</u> Post Weld Heat Treatment Records <u>Per MR, Section III</u> Hydrotest Reports <u>Per MR, Section III</u> Radiographic Inspection Reports <u>Per MR, Section III</u> Ultrasonic Inspection Reports <u>Per MR, Section III</u> Magnetic Particle Inspection Reports <u>Per MR, Section III</u> Dye Penetrant Inspection Reports <u>Per MR, Section III</u> Fabricator Quality Control Manual <u>Per MR, Section III</u> Shop Inspection by Owner <u>Yes</u> Welding Procedure Review/Approval <u>Per MR, Section III</u> * Vendor to specify / Confirm				
DIMENSIONAL/SHIPPING DATA			NOTES				
Vessel Size <u>3960 mm ID</u> x <u>11270 mm S/S</u> Boot/Gas Dome <u>N/A mm OD</u> x <u>N/A mm S/S</u> Capacity <u>152.6 m³</u> Centerline/Bottom Seam Elevation <u>*</u> m Weight - Empty <u>37725 kg</u> Weight - Hydrotest <u>195525 kg</u> Weight - Operatg <u>60030 kg</u> Weight - Shipping <u>39300 kg</u> O/A Shipping Dimensions (LxWxD) <u>*</u> m Nozzle Covers/Connection Plugs <u>Required</u> Shipping Saddles <u>Required</u> Ocean Transport Protection <u>Required (if applicable)</u>			1) Design condition - liquid level shall be 1000mm from bottom seam. Liquid specific gravity shall be considered 1. 2) Structural attachments are defined as any non-pressure part welded directly to the shell or head. 3) All manways shall be completed with internal grab rungs. 4) All davits on inclined manways shall open horizontally. 5) All skirt to shell and lift lug welds shall be MPI examined all around. 6) Seller shall supply the base plate template. 7) All process nozzles of pressure vessels shall be designed to withstand loading and moments as specified in project spec # 085354-4060-PS-001. 8) Nozzles N2 shall be provided with the pipe support and guide type VS-5 and VG-2. Seller shall design and install suitable support clips using the support guide detail drawing and loads supplied by Buyer. Piping loads imposed to the vessel wall shall be considered in the vessel design calculations.				
ACCESSORIES BY FABRICATOR							
Manway Davits <u>Y</u> Ladders <u>N</u> Ladder and Platform Clips <u>N</u> Platforms <u>N</u> Pipe Support and Guide Clips <u>Y</u> Lifting Lugs <u>Y</u> Insulation Supports <u>2</u> <u>N</u> Pipe Coils <u>N</u> Insulation Supports Bottom Head <u>Y</u> Anodes <u>N</u> Fireproofing Supports <u>N</u> Nameplate <u>Y</u> Skirt <u>Y</u> Mist Eliminator <u>N</u> Tray/Packing Supports <u>N</u> Vortex Breaker <u>N</u> Manway Internal Grab Rungs <u>Y</u> Two Grounding Lugs <u>Y</u> Siphon Drains on Nozzles <u>N</u>							
REVISIONS			MEG Energy Corp.				
NO.	DATE	BY	CHK	APP	DESCRIPTION	SNC-LAVALLIN PROJECT <u>MEG Energy Christina Lake Regional Project</u> Phase 3 A	
A	25-May-12	SM	RA	SP	Issued for Squad Check	JOB NO.	508298
B	13-Jun-12	SM	RA	SP	Issued for Quotation	TAG NO.	3A-V-574
0	15-Oct-12	SM	RA	SP	Issued for Purchase	LOCATION	Calgary, Alberta
1	28-Mar-13	WW	AH/RA	CS	Re-issued for Purchase	PAGE	1 of 3
2	5-Sep-13	WW	Charels S.	CS	Re-issued for Purchase		

511036

2B4X

CONNECTION SCHEDULE						
Mark	Nominal Size NPS	Qty	Flange		Service	Projection (Note 9) (mm)
			ASME Class	Type		
N1	6	1	150	RFWN	Inlet	Note 9
N2	6	1	150	RFWN	Outlet	Note 9
N3	6	1	150	RFWN	Vent, c/w blind flange, gasket, bolts & nuts	Note 9
N4	4	1	150	RFWN	Drain	Note 9
N5	2	1	150	RFWN	Auxiliary Relief	Note 9
N6A/B	2	2	150	RFWN	PIT c/w blind flange, gasket, bolts & nuts (Size shall be confirmed during detail engineering)	Note 9
MW1	24	1	150	RFWN	Manway, c/w blind flange, gasket, bolts & nuts, davit	Note 9



- 9) Nozzle projections shall be as per spec. 085354-3010-PV-10 as a minimum, and required projections shall be confirmed during detail engineering.
- 10) Skirt length (measured from bottom head weld seam to underneath of base ring) shall be 1800 mm. To be confirmed during detail engineering.
- 11) Deleted. 2
- 12) Deleted. 2
- 13) Deleted. 2
- 14) Deleted. 2

REVISIONS						MEG Energy Corp.		SNC-LAWALIN	
NO.	DATE	BY	CHK	APP	DESCRIPTION	PROJECT	MEG Energy Christina Lake Regional Project		
A	25-May-12	SM	RA	SP	Issued for Squad Check		Phase 3 A		
B	13-Jun-12	SM	RA	SP	Issued for Quotation				
0	15-Oct-12	SM	RA	SP	Issued for Purchase	JOB NO.	508298	TAG NO.	JA-V-574
1	28-Mar-13	WW	AH/RA	CS	Re-issued for Purchase	LOCATION	Okla, Alberta	PAGE	2 of 3
2	5-Sep-13	WW	Charels S.	CS	Re-issued for Purchase				

511036

2B4X

PROCESS CONDITIONS				
OPERATING CASE				
Fluid			Dry Air	
Operating Pressure	Max/Normal/Min	kPag	365/760/560	
Operating Temperature	Max/Normal/Min	°C	43	
Design Pressure		kPag	1034	
Design Temperature	Max/Min	°C	80/-29	
Slug/Surge Volume		m ³		
Service (Sweet / Sour)				
VAPOUR				
Flowrate		Sm ³ /hr	3385 (Dry Air)	(Note 1)
Density	43°C, and 760 Kpag	kg/m ³	9.442	
Viscosity	43°C, and 760 Kpag	cP	0.0198	
Molecular weight			28.95	
LIQUID AQUEOUS				
Mass Flowrate		kg/h	0 (Normal)	
Density	43°C, and 760 Kpag	kg/m ³	991	
Viscosity		cP	0.62	

Notes:

1) Vessel design flow is 3385 Sm³/hr. However, max estimated flowrate is 3745 Sm³/h (IA Compressor Package Design Flow).

2) The volume of the vessel should not be less than 156.Sm³.

REVISIONS						MEG Energy Corp.		SNC-LAWALIN	
NO.	DATE	BY	CHK	APP	DESCRIPTION	PROJECT	MEG Energy Christina Lake Regional Project		
A	25-May-12	SM	RA	SP	Issued for Squad Check		Phase 3A		
B	13-Jun-12	SM	RA	SP	Issued for Quotation				
0	15-Oct-12	SM	RA	SP	Issued for Purchase	JOB NO.	508298	TAG	JA-V-574
1	28-Mar-13	WV	AH/RA	CS	Re-issued for Purchase	LOCATION	Edmonton, Alberta	PAGE	3 of 3
2	5-Sep-13	WV	Charles S	CS	Re-issued for Purchase				

511036

2B4X