


 <b>MEG ENERGY</b>	<b>CHRISTINA LAKE REGIONAL PROJECT</b> <b>Phase 3A EPC for Central Plant Facilities</b>	 <b>SNC-LAVALIN</b>
<b>SLI Project No. 511036</b>		

 <b>SNC-LAVALIN</b>	<table border="0"> <tr> <td><input type="checkbox"/> A1</td> <td>Not suitable to initiate fabrication; modify as noted, resubmit for review</td> </tr> <tr> <td><input type="checkbox"/> B1</td> <td>Suitable to initiate fabrication as noted; modify as noted, resubmit for review</td> </tr> <tr> <td><input type="checkbox"/> C1</td> <td>Suitable to fabricate to completion as noted; submit final documents including as-builts as required</td> </tr> <tr> <td><input type="checkbox"/> D1</td> <td>Suitable to fabricate to completion; submit final documents including as-built documents as required</td> </tr> <tr> <td><input type="checkbox"/> E1</td> <td>Not suitable as final documents as noted; modify as noted and resubmit</td> </tr> <tr> <td><input checked="" type="checkbox"/> F1</td> <td>Suitable as final documents; no further resubmittal required (unless revised by vendor)</td> </tr> </table>	<input type="checkbox"/> A1	Not suitable to initiate fabrication; modify as noted, resubmit for review	<input type="checkbox"/> B1	Suitable to initiate fabrication as noted; modify as noted, resubmit for review	<input type="checkbox"/> C1	Suitable to fabricate to completion as noted; submit final documents including as-builts as required	<input type="checkbox"/> D1	Suitable to fabricate to completion; submit final documents including as-built documents as required	<input type="checkbox"/> E1	Not suitable as final documents as noted; modify as noted and resubmit	<input checked="" type="checkbox"/> F1	Suitable as final documents; no further resubmittal required (unless revised by vendor)
<input type="checkbox"/> A1	Not suitable to initiate fabrication; modify as noted, resubmit for review												
<input type="checkbox"/> B1	Suitable to initiate fabrication as noted; modify as noted, resubmit for review												
<input type="checkbox"/> C1	Suitable to fabricate to completion as noted; submit final documents including as-builts as required												
<input type="checkbox"/> D1	Suitable to fabricate to completion; submit final documents including as-built documents as required												
<input type="checkbox"/> E1	Not suitable as final documents as noted; modify as noted and resubmit												
<input checked="" type="checkbox"/> F1	Suitable as final documents; no further resubmittal required (unless revised by vendor)												
Vendor's drawing review for conformity with specifications and design drawing.													
This review does not relieve the vendor of his responsibility for errors in design and detailing as detailed in his contract.													



Vendor: Sewon Cellontech Co. Ltd. - P00007	No.: E0351-3AE101-P-02	Rev: 0	Date Rec'd
Doc. Title: L53.51, L53.53 - THERMAL DESIGN CALCULATION - Tag:3A-E-101A/B	2013/09/04		
Client Code:	Project: MEG Phase 3A EPC		
Reviewed by: <i>SS</i>	Document No	Submittal	
Date: <i>11-Sept-2013</i>	P-5310-01-0031	02	



 <b>SEWON CELLONTECH</b>	<b>DOCUMENT FOR EQUIPMENT</b>	SWC JOB NO	E-0351
		ITEM NO.	3A-E-101A/B
		SWC DOC. NO.	E0351-3AE101-P-02

**ASME-U**

**FOR APPROVAL**

 <b>MEG Energy Corp.</b>		 <b>SNC-LAVALIN</b>	
P.O NO.		P-5310-01	
PROJECT NAME	CLRP Phase 3A Central Plant Facility: EPC		
PROJECT NO.	511036		
DOCUMENT TITLE	THERMAL DESIGN CALCULATION		
ITEM NO.	ITEM DESCRIPTION		
3A-E-101A/B	PRODUCED GAS / BFW EXCHANGER		



- Total Sheet : 20 Sheet (Including This Cover)

1	M.K. Park 8/16/2013	T.W. Kim 8/16/13	Y.S. Ji 8/21/2013	SECOND ISSUE
0	M.K.PARK	T.W.KIM	Y.S.JI	FIRST ISSUED
REV	PREPARED BY	REVIEWED BY	APPROVED BY	DESCRIPTION

**SEWON CELLONTECH CO.,LTD.**







SHEET 3 OF 20

(16) EHT design shall use voltage of 277 VAC.



SEWON CELLONTECH

## TUBULAR HEAT EXCHANGER

SHEET 4 OF 20

CUSTOMER	MEG Energy Corp.	REV	MADE BY	CHECKED BY	APPROVED BY	DATE
LOCATION	CANADA	0	-	-	-	07-01-2013
JOB NO.	511036	1	-	-	-	08-14-2013
SERVICE	Produced Gas / BFW Exchanger					
ITEM NO.	3A-E-101A/B (Start-Up Case)					

Total	2	Shells, Connected in	2	Parallel	1	Series Shells	Install	<input checked="" type="checkbox"/> Hor. <input type="checkbox"/> Vert.	Size	1,100.0 ID - 12,192.0 L
Code	ASME Sec.VIII Div.1 (STAMP), TEMA, API660	TEMA Type	AEL	TEMA Class	R	Effective Area	929.53 (Note 1)	m <sup>2</sup> /Shell		

## PERFORMANCE OF ONE BATTERY

			SHELL SIDE				TUBE SIDE				
			INLET		OUTLET		INLET		OUTLET		
Fluid Circulated			BFW				Produced Gas				
Total Fluid	kg/hr		669128				139760				
Vapor	kg/hr	MW					139760		78968.7		
Liquid	kg/hr	MW	669128		669128				60790.8		
Steam	kg/hr										
Water	kg/hr		669128		669128						
Noncondensable	kg/hr	MW									
Operating Temperature	°C		98.30		146.00		166.00		151.20		
Operating Pressure	kPag		2850.04				984.014				
Density	kg/m3	L / V	960.84		922.04		4.9464		899.83		4.9422
Viscosity	cP	L / V	0.2876		0.1884		0.0125		0.1758		0.0131
Thermal Conductivity	W/m·°C	L / V	0.6787		0.6862		0.0373		0.6791		0.0402
Specific Heat	kJ/kg·°C	L / V	4.2084		4.2928		2.1575		4.5883		2.2325
Latent Heat	kJ/kg										
Bubble / Dew Point	°C		/		/		/		/		
Critical Press. / Temp.	kPag / °C		/		/		/		/		
Velocity	m/sec		0.60				9.43				
Pressure Drop	kPa		Allow.	105.002	Calc.	48.042	Allow.	15.000	Calc.	11.738	
Fouling Resistance	m2·°C/kW		0.18				0.35				
Film Coefficient	W/m2·K		8,396.34				7,264.35				
Overall Coefficient	W/m2·K		Clean	3066.42	Calc.		1080.08	Design	581.08		
Heat Duty	KW		38,155.00				LMTD	°C	MTD	34.8	°C

## CONSTRUCTION

Design Pressure	Design Temperature	/ kPag		/ °C		/ kPag		/ °C	
No. of Passes									
Tubes No.	/ Shell	Size	mm	Thickness	(Min.) mm	( BWG : )	Length	mm	
Shell		mm ID		Tube Pitch	mm	Layout angle °	Effective	- mm	
Baffles	Cross Baffle	ea / Shell	Type	Cut	- % Dia.	Spacing c/c	mm	End	- mm
qv²	Inlet Nozzle	1,916.26	Entrance	2,481.69	Outlet Nozzle	1,996.90	kg/m·sec²	Impingement plate	
Material	Tube				Shell & Cover		Channel & Cover		
	Tube Sheet				Baffle		Expansion Joint		
Estimated Weight	Empty Weight	kg		Bundle Weight		kg		Full Water Weight	
Corrosion Allowance	Shell side	mm		Tube side	mm		Tube Joints :		
Insulation	Shell side	mm		Tube side	mm				



INSULATION		SHELL SIDE				TUBE SIDE			
MEAN METAL		Temperature, °C				Pressure, kPag			
TEMPERATURE		Shell		Tube		Shell		Tube	
Normal Operating		-		-		-		-	
Startup		-		-		-		-	
NOZZLE		SHELL SIDE				TUBE SIDE			
		Tag	No	NPS	Remarks	Tag	No	NPS	Remarks
Inlet									
Outlet									
Vent									
Drain									
Liquid Outlet									
Thermowell									
Util. Con.									
RATING									



## TUBULAR HEAT EXCHANGER


SHEET 6 OF 20

CUSTOMER	MEG Energy Corp.	REV	MADE BY	CHECKED BY	APPROVED BY	DATE
LOCATION	CANADA	0	-	-	-	07-01-2013
JOB NO.	511036	1	-	-	-	08-14-2013
SERVICE	Produced Gas / BFW Exchanger					
ITEM NO.	3A-E-101A/B					






CUSTOMER	MEG Energy Corp.	REV	MADE BY	CHECKED BY	APPROVED BY	DATE
LOCATION	CANADA	0	-	-	-	07-01-2013
JOB NO.	511036	1	-	-	-	08-14-2013
SERVICE	Produced Gas / BFW Exchanger					
ITEM NO.	3A-E-101A/B					



3A-E-101

$$\frac{1}{5}$$

I.D.-SHELL	1,100.0 ID	(AEL)
ALLOWABLE O.T.L	1074.6	mm
ACTUAL O.T.L	1074.6	mm
SEAL STRIP	N/A	Pairs
SEAL Rod	N/A	ea

TOTAL 968 HOLES FOR 25.4 OD TUBES ON 31.75 TRIANGULAR PITCH.  
1 PASSES. BAFFLE CUT SINGLE SEGM. 25% DIA.

Remarks



# **Thermal/Hydraulic/ Vibration** **Verification Report**

(Rev.1)

**3A-E-101A/B**

**Client :** MEG Energy Corp.

**Project :** MEG Energy Christina Lake Regional Project  
Phase 3A-Central Plant Facilities

**Date :** 08-14-2013

## 3A-E-101A/B (Max Duty and UA Case)

The Thermal/Hydraulic/Vibration calculations are performed by using HTRI Xist Ver. 6.00 SP3.

The process condition and the physical properties are based on Buyer data sheet.

For the design result ( the geometry data), please refer to the Equipment data sheet and Fabrication drawing.

### 1. Thermal and Hydraulic performance

- Thermal performance :	<u>1.94</u>	% Over - Design Case	-----	O.K.
- Pressure drop :				
Shell-side	<u>48.264</u>	<	105.000 kPa	----- O.K
tube-side	<u>3.982</u>	<	15.000 kPa	----- O.K

### 2. Vibration Analysis

- Fluidelastic instability :	characteristic values	<<	criteria	-----	O.K.
- Acoustic vibration :	characteristic values	<<	criteria	-----	O.K.
- Tube vibration check:	characteristic values	<<	criteria	-----	O.K.
- Bundle Entrance/Exit :	characteristic values	<<	criteria	-----	O.K.
- Shell Entrance /Exit:	characteristic values	<<	criteria	-----	O.K.

### 3A-E-101A/B (Max Duty and UA Case)

Used Program : HTRI Xist Ver.6.00 SP.3 Vibration Analysis

VALUE TO BE CHECKED	Inlet	Center	Outlet	RECOMMEND LIMIT	CONCLUSION
Unsupported span (mm)	1511.	1060.	1511.	1879 (By TEMA)	O.K
Length / TEMA maximum span	0.804	0.564	0.804	< 1.0 TEMA	O.K
Fluidelastic Instability Check					
Baffle tip cross velocity ratio	0.1500	0.1434	0.1565	< 0.8	O.K
Ave. crossflow velocity ratio	0.1385	0.1324	0.1445	< 0.8	O.K
Acoustic Vibration Check					
Vortex shedding ratio	-	-	-	-	-
Tubulent buffeting ratio	-	-	-	-	-
Tube Vibration Check					
Vortex shedding ratio	0.059	0.115	0.062	< 0.5	O.K
Tubulent buffeting ratio	-	-	-	-	-
Bundle Entrance / Exit		Entrance	Exit		
Fluidelastic Instability ratio		0.200	0.202	< 0.8	O.K
Vortex shedding ratio		0.201	0.207	< 0.5	O.K
Shell Entrance / Exit					
Velocity (m/sec)		1.61	2.34	< If velocity is exceed 2.23 / 2.27	O.K.
pv2 (kg/m-s2)		2481.69	4952.99	< 5953 by TEMA	O.K.

11/20

<b>Vibration Analysis</b> Released to the following HTRI Member Company: <i>sewon</i> <i>M.K.Park</i>				
Xist Ver. 6.00 SP3 2013/08/19 14:06 SN: 1500213869			MEG Energy Units	
Max. Duty and UA Case				
Rating - Incline Countercurrent Flow TEMA AEL Shell With Single-Segmental Baffles				
1	Shellside condition	Sens. Liquid	(Level 2.3)	
2	Axial stress loading (MPa)	0.000	Added mass factor	1.761
3	Beta	4.000		
4	Position In The Bundle	Inlet	Center	Outlet
5	Length for natural frequency (mm)	1511.	1060.	1511.
6	Length/TEMA maximum span (---)	0.804 *	0.564	0.804 *
7	Number of spans (---)	11	11	11
8	Tube natural frequency (Hz)	38.0 +	45.2	38.5
9	Shell acoustic frequency (Hz)			
10	Flow Velocities	Inlet	Center	Outlet
11	Window parallel velocity (m/s)	0.84	0.87	0.89
12	Bundle crossflow velocity (m/s)	0.31	0.61	0.33
13	Bundle/shell velocity (m/s)	0.32	0.62	0.34
14	Fluidelastic Instability Check	Inlet	Center	Outlet
15	Log decrement HTRI	0.100	0.100	0.100
16	Critical velocity (m/s)	2.23	4.57	2.27
17	Baffle tip cross velocity ratio (---)	0.1500	0.1434	0.1565
18	Average crossflow velocity ratio (---)	0.1385	0.1324	0.1445
19	Acoustic Vibration Check	Inlet	Center	Outlet
20	Vortex shedding ratio (---)			
21	Chen number (---)			
22	Turbulent buffeting ratio (---)			
23	Tube Vibration Check	Inlet	Center	Outlet
24	Vortex shedding ratio (---)	0.059	0.115	0.062
25	Parallel flow amplitude (mm)	0.002	0.003	0.002
26	Crossflow amplitude (mm)	0.039	0.035	0.041
27	Tube gap (mm)	6.350	6.350	6.350
28	Crossflow RHO-V-SQ (kg/m-s2)	91.49	340.24	97.15
29	Bundle Entrance/Exit			
30	(analysis at first tube row)		Entrance	Exit
31	Fluidelastic instability ratio (---)		0.200	0.202
32	Vortex shedding ratio (---)		0.201	0.207
33	Crossflow amplitude (mm)		0.08360	0.08364
34	Crossflow velocity (m/s)		1.06	1.09
35	Tubesheet to inlet/outlet support (mm)		None	None
36	Shell Entrance/Exit Parameters		Entrance	Exit
37	Impingement plate		Yes	
38	Flow area (m2)		0.060	0.044
39	Velocity (m/s)		1.61	2.34
40	RHO-V-SQ (kg/m-s2)		2481.69	4952.99
41	Shell type AEL	Baffle type	Single-Seg.	
42	Tube type Plain	Baffle layout	Perpend.	
43	Pitch ratio 1.2500	Tube diameter, (mm)	25.400	
44	Layout angle 30	Tube material	Carbon steel	
45	Supports/baffle space			
46	Program Messages			
47	+ Frequency ratios are based upon lowest natural or acoustic frequency			
48	* Items with asterisk exceed a conservative lower limit for vibration-free design. Review your case			
49	using the procedure described in Online Help; You may find that a vibration problem is unlikely.			
50				
51				
52				
53				



12/20

Final Results									
Released to the following HTRI Member Company:									
<div>sewon</div> <div>M.K.Park</div>									
Xist Ver. 6.00 SP3 2013/08/19 14:06 SN: 1500213869					MEG Energy Units				
Max. Duty and UA Case									
Rating - Incline Countercurrent Flow TEMA AEL Shell With Single-Segmental Baffles									
1	Process Data		Cold Shellside		Hot Tubeside		Shellside Performance		
2	Fluid name	BFW		Produced Gas		Nom vel, X-flow/window 0.82 / 1.00			
3	Fluid condition	Sens. Liquid		Cond. Vapor		Flow fractions for heat transfer 0.663			
4	Total flow rate	(kg/hr)	669128			A=0.1305 B=0.6260 C=0.0820 E=0.1614 F=0.0000			
5	Weight fraction vapor, In/Out	(--)	0.000	0.000	1.000	0.180			
6	Temperature, In/Out	(Deg C)	98.30	164.00	174.00	136.30			
7	Temperature, Average/Skin	(Deg C)	131.15	139.01	155.15	157.94			
8	Wall temperature, Min/Max	(Deg C)	106.57	167.30	107.66	167.82			
9	Pressure, In/Average	(kPa)	2850.04	2825.91	984.014	982.023			
10	Pressure drop, Total/Allowed	(kPa)	48.264	105.000	3.982	15.000			
11	Velocity, Mid/Max allow	(m/s)	0.61		5.45				
12	Mole fraction inert	(--)				0.0000			
13	Average film coef.	(W/m2-K)		8691.24		5771.16			
14	Heat transfer safety factor	(--)		1.000		1.000			
15	Fouling resistance	(m2-K/W)		0.000180		0.000350			
16	Overall Performance Data								
17	Overall coef., Req'd/Clean/Actual	(W/m2-K)	1016.73	/	2739.43	/	1036.50		
18	Heat duty, Calculated/Specified	(kW)	52093.	/	52017.				
19	Effective overall temperature difference	(Deg C)	27.5						
20	EMTD = (MTD) * (DELTA) * (F/G/H)	(Deg C)	28.26	*	0.9739	*	1.0000		
21									
22									
23	See Runtime Messages Report for								
24	warnings.								
25									
26	Exchanger Fluid Volumes								
27	Approximate shellside (L)		5464.3						
28	Approximate tubeside (L)		6224.3						
29	Shell Construction Information								
30	TEMA shell type	AEL	Shell ID	(mm)	1100.00				
31	Shells Series	1 Parallel 2	Total area	(m2)	1883.47				
32	Passes Shell	1 Tube 1	Eff. area	(m2/shell)	929.377				
33	Shell orientation angle (deg)	1.00							
34	Impingement present	Rectangular plate	Imp. length/width (mm)	400 / 400					
35	Pairs seal strips	0	Passlane seal rods (mm)	0.000	No. 0				
36	Shell expansion joint	No	Rear head support plate	No					
37	Weight estimation Wet/Dry/Bundle		46228.1 / 34547.6 / 15724.4	(kg/shell)					
38									
39	Baffle Information								
40	Type	Perpend. Single-Seg.	Baffle cut (% dia)	25.00					
41	Crosspasses/shellpass	21	No. (Pct Area)	(mm) to C.L					
42	Central spacing	(mm) 530.000	1	21.86	275.000				
43	Inlet spacing	(mm) 980.939	2	0.00	0.000				
44	Outlet spacing	(mm) 980.939							
45	Baffle thickness	(mm) 12.700							
46									
47									
48	Tube Information								
49	Tube type	Plain	Tubecount per shell	968					
50	Overall length	(mm) 12192.	Pct tubes removed (both)	3.72					
51	Effective length	(mm) 12032.	Outside diameter	(mm) 25.400					
52	Total tubesheet	(mm) 160.000	Wall thickness	(mm) 2.110					
53	Area ratio	(out/in) 1.1992	Pitch (mm)	31.7500	Ratio	1.2500			
54	Tube metal	Carbon steel	Tube pattern (deg)	30					
							Shell Nozzles		
							Inlet	Outlet	Liquid
							1	1	0
							Diameter	(mm) 295.301	295.301
							Velocity	(m/s) 1.41	1.50
							Pressure drop	(kPa) 2.447	2.944
							Height under nozzle	(mm) 75.000	42.666
							Nozzle R-V-SQ	(kg/m-s2) 1916.26	2034.92
							Shell ent.	(kg/m-s2) 2481.69	4952.99
							Tube Nozzle		
							Inlet	Outlet	Liquid
							RADIAL	RADIAL	Outlet
							Diameter	(mm) 380.400	295.301
							Velocity	(m/s) 24.73	6.70
							Pressure drop	(kPa) 1.718	0.491
							Nozzle R-V-SQ	(kg/m-s2) 3122.34	1402.93
							Annular Distributor		
							Inlet	Outlet	
							Length	(mm)	
							Height	(mm)	
							Slot area	(mm2)	
							Diametral Clearances (mm)		
							Baffle-to-shell	Bundle-to-shell	Tube-to-baffle
							6.3500	25.4000	0.3969

## 3A-E-101A/B (Min Case)

13 of 20

The Thermal/Hydraulic/Vibration calculations are performed by using HTRI Xist Ver. 6.00 SP3.

The process condition and the physical properties are based on Buyer DATA SHEET (2).

For the design result ( the geometry data), please refer to the Equipment DATA SHEET (2) and Fabrication drawing.

### 1. Thermal and Hydraulic performance

- Thermal performance :	<u>95.56</u>	% Over - Design Case	-----	O.K.
- Pressure drop :				
Shell-side	<u>33.175</u>	<	105.000 kPa	----- O.K
tube-side	<u>0.254</u>	<	15.000 kPa	----- O.K

### 2. Vibration Analysis

- Fluidelastic instability :	characteristic values	<<	criteria	-----	O.K.
- Acoustic vibration :	characteristic values	<<	criteria	-----	O.K.
- Tube vibration check:	characteristic values	<<	criteria	-----	O.K.
- Bundle Entrance/Exit :	characteristic values	<<	criteria	-----	O.K.
- Shell Entrance /Exit:	characteristic values	<<	criteria	-----	O.K.

## 3A-E-101A/B (Min Case)

Used Program : HTRI Xist Ver.6.00 SP.3 Vibration Analysis

VALUE TO BE CHECKED	Inlet	Center	Outlet	RECOMMEND LIMIT	CONCLUSION
Unsupported span (mm)	1511.	1060.	1511.	1879 (By TEMA)	O.K
Length / TEMA maximum span	0.804	0.564	0.804	< 1.0 TEMA	O.K
Fluidelastic Instability Check					
Baffle tip cross velocity ratio	0.1234	0.1153	0.1253	< 0.8	O.K
Ave. crossflow velocity ratio	0.1139	0.1064	0.1157	< 0.8	O.K
Acoustic Vibration Check					
Vortex shedding ratio	-	-	-	-	-
Tubulent buffeting ratio	-	-	-	-	-
Tube Vibration Check					
Vortex shedding ratio	0.048	0.092	0.049	< 0.5	O.K
Tubulent buffeting ratio	-	-	-	-	-
Bundle Entrance / Exit		Entrance	Exit		
Fluidelastic Instability ratio		0.165	0.162	< 0.8	O.K
Vortex shedding ratio		0.166	0.164	< 0.5	O.K
Shell Entrance / Exit					
Velocity (m/sec)		1.32	1.86	< If velocity is exceed 2.23 / 2.24	O.K.
pv2 (kg/m-s2)		1685.46	3239.12	< 5953 by TEMA	O.K.

15/20

**Vibration Analysis**

Released to the following HTRI Member Company:

sewon

M.K.Park

Xist Ver. 6.00 SP3 2013/08/19 14:07 SN: 1500213869

MEG Energy Units

Min. Case

Rating - Incline Countercurrent Flow TEMA AEL Shell With Single-Segmental Baffles

1	Shellside condition		Sens. Liquid	(Level 2.3)	
2	Axial stress loading	(MPa)	0.000	Added mass factor	1.761
3	Beta		4.000		
4	Position In The Bundle		Inlet	Center	Outlet
5	Length for natural frequency	(mm)	1511.	1060.	1511.
6	Length/TEMA maximum span	(--)	0.804 *	0.564	0.804 *
7	Number of spans	(--)	11	11	11
8	Tube natural frequency	(Hz)	38.0 +	44.9	38.2
9	Shell acoustic frequency	(Hz)			
10	Flow Velocities		Inlet	Center	Outlet
11	Window parallel velocity	(m/s)	0.69	0.69	0.70
12	Bundle crossflow velocity	(m/s)	0.25	0.48	0.26
13	Bundle/shell velocity	(m/s)	0.26	0.49	0.26
14	Fluidelastic Instability Check		Inlet	Center	Outlet
15	Log decrement	HTRI	0.100	0.100	0.100
16	Critical velocity	(m/s)	2.23	4.53	2.24
17	Baffle tip cross velocity ratio	(--)	0.1234	0.1153	0.1253
18	Average crossflow velocity ratio	(--)	0.1139	0.1064	0.1157
19	Acoustic Vibration Check		Inlet	Center	Outlet
20	Vortex shedding ratio	(--)			
21	Chen number	(--)			
22	Turbulent buffeting ratio	(--)			
23	Tube Vibration Check		Inlet	Center	Outlet
24	Vortex shedding ratio	(--)	0.048	0.092	0.049
25	Parallel flow amplitude	(mm)	0.001	0.002	0.001
26	Crossflow amplitude	(mm)	0.026	0.023	0.027
27	Tube gap	(mm)	6.350	6.350	6.350
28	Crossflow RHO-V-SQ	(kg/m-s2)	61.86	222.84	63.25
29	Bundle Entrance/Exit				
30	(analysis at first tube row)			Entrance	Exit
31	Fluidelastic instability ratio	(--)		0.165	0.162
32	Vortex shedding ratio	(--)		0.166	0.164
33	Crossflow amplitude	(mm)		0.05603	0.05381
34	Crossflow velocity	(m/s)		0.87	0.86
35	Tubesheet to inlet/outlet support	(mm)		None	None
36	Shell Entrance/Exit Parameters			Entrance	Exit
37	Impingement plate			Yes	
38	Flow area	(m2)		0.060	0.044
39	Velocity	(m/s)		1.32	1.86
40	RHO-V-SQ	(kg/m-s2)		1685.46	3239.12
41	Shell type	AEL	Baffle type	Single-Seg.	
42	Tube type	Plain	Baffle layout	Perpend.	
43	Pitch ratio	1.2500	Tube diameter, (mm)	25.400	
44	Layout angle	30	Tube material	Carbon steel	
45	Supports/baffle space				

**Program Messages**

+ Frequency ratios are based upon lowest natural or acoustic frequency

\* Items with asterisk exceed a conservative lower limit for vibration-free design. Review your case using the procedure described in Online Help; You may find that a vibration problem is unlikely.



16/20

Final Results									
Released to the following HTRI Member Company:									
<div>sewon</div> <div>M.K.Park</div>									
Xist Ver. 6.00 SP3 2013/08/19 14:07 SN: 1500213869					MEG Energy Units				
Min. Case									
Rating - Incline Countercurrent Flow TEMA AEL Shell With Single-Segmental Baffles									
1	Process Data		Cold Shellside		Hot Tubeside		Shellside Performance		
2	Fluid name	BFW		Produced Gas		Nom vel, X-flow/window 0.66 / 0.79			
3	Fluid condition	Sens. Liquid		Cond. Vapor		Flow fractions for heat transfer 0.661			
4	Total flow rate	(kg/hr)	551436			A=0.1307 B=0.6246 C=0.0798 E=0.1649 F=0.0000			
5	Weight fraction vapor, In/Out	(--)	0.000	0.000	1.000	0.133			
6	Temperature, In/Out	(Deg C)	98.30	125.80	174.30	108.30			
7	Temperature, Average/Skin	(Deg C)	112.05	107.48	141.30	119.50			
8	Wall temperature, Min/Max	(Deg C)	98.84	140.91	98.91	142.93			
9	Pressure, In/Average	(kPa)	2850.04	2833.45	984.014	983.888			
10	Pressure drop, Total/Allowed	(kPa)	33.175	105.000	0.254	15.000			
11	Velocity, Mid/Max allow	(m/s)	0.48		0.38				
12	Mole fraction inert	(--)				0.0000			
13	Average film coef.	(W/m2-K)		6943.65		732.08			
14	Heat transfer safety factor	(--)		1.000		1.000			
15	Fouling resistance	(m2-K/W)		0.000180		0.000350			
16	Overall Performance Data								
17	Overall coef., Req'd/Clean/Actual	(W/m2-K)	210.95	/	548.14	/	412.53		
18	Heat duty, Calculated/Specified	(kW)	17779.	/	17752.				
19	Effective overall temperature difference	(Deg C)	45.3						
20	EMTD = (MTD) * (DELTA) * (F/G/H)	(Deg C)	45.36	*	0.9982	*	1.0000		
21									
22									
23	See Runtime Messages Report for warnings.								
24									
25									
26	Exchanger Fluid Volumes								
27	Approximate shellside (L)	5464.3							
28	Approximate tubeside (L)	6224.3							
29	Shell Construction Information								
30	TEMA shell type	AEL	Shell ID	(mm)	1100.00				
31	Shells Series	1 Parallel 2	Total area	(m2)	1883.47				
32	Passes Shell	1 Tube 1	Eff. area	(m2/shell)	929.377				
33	Shell orientation angle (deg)	1.00							
34	Impingement present	Rectangular plate	Imp. length/width (mm)	400 / 400					
35	Pairs seal strips	0	Passlane seal rods (mm)	0.000	No. 0				
36	Shell expansion joint	No	Rear head support plate	No					
37	Weight estimation Wet/Dry/Bundle	46227.9 /	34547.4 /	15724.3 (kg/shell)					
38									
39	Baffle Information								
40	Type	Perpend. Single-Seg.	Baffle cut (% dia)	25.00					
41	Crosspasses/shellpass	21	No. (Pct Area)	(mm) to C.L					
42	Central spacing	(mm) 530.000	1	21.86	275.000				
43	Inlet spacing	(mm) 980.939	2	0.00	0.000				
44	Outlet spacing	(mm) 980.939							
45	Baffle thickness	(mm) 12.700							
46									
47									
48	Tube Information								
49	Tube type	Plain	Tube count per shell	968					
50	Overall length	(mm) 12192.	Pct tubes removed (both)	3.72					
51	Effective length	(mm) 12032.	Outside diameter	(mm) 25.400					
52	Total tubesheet	(mm) 160.000	Wall thickness	(mm) 2.110					
53	Area ratio	(out/in) 1.1992	Pitch (mm)	31.7500	Ratio	1.2500			
54	Tube metal	Carbon steel	Tube pattern (deg)	30					
							Shell Nozzles		
Inlet at channel end-No							Inlet	Outlet	Liquid Outlet
Number at each position							1	1	0
Diameter							(mm) 295.301	295.301	
Velocity							(m/s) 1.16	1.19	
Pressure drop							(kPa) 1.672	1.953	
Height under nozzle							(mm) 75.000	42.666	
Nozzle R-V-SQ							(kg/m-s2) 1301.45	1330.76	
Shell ent.							(kg/m-s2) 1685.46	3239.12	
							Tube Nozzle		
							Inlet	Outlet	Liquid Outlet
Diameter							(mm) 380.400	295.301	
Velocity							(m/s) 7.45	1.34	
Pressure drop							(kPa) 0.161	0.031	
Nozzle R-V-SQ							(kg/m-s2) 293.56	87.75	
							Annular Distributor		
							Inlet	Outlet	
Length							(mm)		
Height							(mm)		
Slot area							(mm2)		
							Diametral Clearances (mm)		
Baffle-to-shell							Bundle-to-shell	Tube-to-baffle	
6.3500							25.4000	0.3969	

## 3A-E-101A/B (Start-Up Case)

17 of 20

The Thermal/Hydraulic/Vibration calculations are performed by using HTRI Xist Ver. 6.00 SP3.

The process condition and the physical properties are based on Buyer DATA SHEET (3).

For the design result ( the geometry data), please refer to the Equipement DATA SHEET (3) and Fabrication drawing.

### 1. Thermal and Hydraulic performance

- Thermal performance :	<u>85.88</u>	% Over - Design Case	-----	O.K.
- Pressure drop :				
Shell-side	<u>48.042</u>	<	105.000 kPa	----- O.K.
tube-side	<u>11.738</u>	<	15.000 kPa	----- O.K.

### 2. Vibration Analysis

- Fluidelastic instability :	characteristic values	<<	criteria	-----	O.K.
- Acoustic vibration :	characteristic values	<<	criteria	-----	O.K.
- Tube vibration check:	characteristic values	<<	criteria	-----	O.K.
- Bundle Entrance/Exit :	characteristic values	<<	criteria	-----	O.K.
- Shell Entrance /Exit:	characteristic values	<<	criteria	-----	O.K.

### 3A-E-101A/B (Min Case)

Used Program : HTRI Xist Ver.6.00 SP.3 Vibration Analysis

VALUE TO BE CHECKED	Inlet	Center	Outlet	RECOMMEND LIMIT	CONCLUSION
Unsupported span (mm)	1511.	1060.	1511.	1879 (By TEMA)	O.K
Length / TEMA maximum span	0.804	0.564	0.804	< 1.0 TEMA	O.K
Fluidelastic Instability Check.					
Baffle tip cross velocity ratio	0.1498	0.1420	0.1542	< 0.8	O.K
Ave. crossflow velocity ratio	0.1383	0.1311	0.1423	< 0.8	O.K
Acoustic Vibration Check					
Vortex shedding ratio	-	-	-	-	-
Tubulent buffeting ratio	-	-	-	-	-
Tube Vibration Check					
Vortex shedding ratio	0.059	0.114	0.061	< 0.5	O.K
Tubulent buffeting ratio	-	-	-	-	-
Bundle Entrance / Exit		Entrance	Exit		
Fluidelastic Instability ratio		0.200	0.199	< 0.8	O.K
Vortex shedding ratio		0.201	0.203	< 0.5	O.K
Shell Entrance / Exit					
Velocity (m/sec)		1.61	2.30	< If velocity is exceed 2.23 / 2.26	O.K.
pv2 (kg/m-s <sup>2</sup> )		2481.69	4860.53	< 5953 by TEMA	O.K.

19/20

**Vibration Analysis**

Released to the following HTRI Member Company:

sewon  
M.K.Park

Xist Ver. 6.00 SP3 2013/08/19 14:08 SN: 1500213869

MEG Energy Units

Start-up Case

Rating - Incline Countercurrent Flow TEMA AEL Shell With Single-Segmental Baffles


1	Shellside condition		Sens. Liquid	(Level 2.3)	
2	Axial stress loading	(MPa)	0.000	Added mass factor	1.761
3	Beta		4.000		
4	Position In The Bundle		Inlet	Center	Outlet
5	Length for natural frequency	(mm)	1511.	1060.	1511.
6	Length/TEMA maximum span	(--)	0.804 *	0.564	0.804 *
7	Number of spans	(--)	11	11	11
8	Tube natural frequency	(Hz)	38.1 +	45.1	38.4
9	Shell acoustic frequency	(Hz)			
10	Flow Velocities		Inlet	Center	Outlet
11	Window parallel velocity	(m/s)	0.84	0.86	0.87
12	Bundle crossflow velocity	(m/s)	0.31	0.60	0.32
13	Bundle/shell velocity	(m/s)	0.32	0.61	0.33
14	Fluidelastic Instability Check		Inlet	Center	Outlet
15	Log decrement	HTRI	0.100	0.100	0.100
16	Critical velocity	(m/s)	2.23	4.56	2.26
17	Baffle tip cross velocity ratio	(--)	0.1498	0.1420	0.1542
18	Average crossflow velocity ratio	(--)	0.1383	0.1311	0.1423
19	Acoustic Vibration Check		Inlet	Center	Outlet
20	Vortex shedding ratio	(--)			
21	Chen number	(--)			
22	Turbulent buffeting ratio	(--)			
23	Tube Vibration Check		Inlet	Center	Outlet
24	Vortex shedding ratio	(--)	0.059	0.114	0.061
25	Parallel flow amplitude	(mm)	0.002	0.003	0.002
26	Crossflow amplitude	(mm)	0.038	0.035	0.040
27	Tube gap	(mm)	6.350	6.350	6.350
28	Crossflow RHO-V-SQ	(kg/m-s2)	91.43	336.20	95.27
29	Bundle Entrance/Exit				
30	(analysis at first tube row)			Entrance	Exit
31	Fluidelastic instability ratio	(--)		0.200	0.199
32	Vortex shedding ratio	(--)		0.201	0.203
33	Crossflow amplitude	(mm)		0.08337	0.08172
34	Crossflow velocity	(m/s)		1.06	1.07
35	Tubesheet to inlet/outlet support	(mm)		None	None
36	Shell Entrance/Exit Parameters			Entrance	Exit
37	Impingement plate			Yes	
38	Flow area	(m2)		0.060	0.044
39	Velocity	(m/s)		1.61	2.30
40	RHO-V-SQ	(kg/m-s2)		2481.69	4860.53
41	Shell type	AEL	Baffle type	Single-Seg.	
42	Tube type	Plain	Baffle layout	Perpend.	
43	Pitch ratio	1.2500	Tube diameter, (mm)	25.400	
44	Layout angle	30	Tube material	Carbon steel	
45			Supports/baffle space		

**Program Messages**

- 47 + Frequency ratios are based upon lowest natural or acoustic frequency
- 48 \* Items with asterisk exceed a conservative lower limit for vibration-free design. Review your case
- 49 using the procedure described in Online Help; You may find that a vibration problem is unlikely.



20/20

Final Results													
Released to the following HTRI Member Company:													
sewon													
M.K.Park													
Xist Ver. 6.00 SP3 2013/08/19 14:08 SN: 1500213869					MEG Energy Units								
Start-up Case													
Rating - Incline Countercurrent Flow TEMA AEL Shell With Single-Segmental Baffles													
1	Process Data			Cold Shellside		Hot Tubeside		Shellside Performance					
2	Fluid name BFW					Produced Gas		Nom vel, X-flow/window 0.81 / 0.98					
3	Fluid condition Sens. Liquid					Cond. Vapor		Flow fractions for heat transfer 0.662					
4	Total flow rate (kg/hr) 669128					139760		A=0.1310 B=0.6258 C=0.0813 E=0.1619 F=0.0000					
5	Weight fraction vapor, In/Out (-) 0.000			0.000		1.000							
6	Temperature, In/Out (Deg C) 98.30			146.00		166.00		151.20					
7	Temperature, Average/Skin (Deg C) 122.15			129.56		158.60		154.10					
8	Wall temperature, Min/Max (Deg C) 114.43			152.79		116.59		153.76					
9	Pressure, In/Average (kPa) 2850.04			2826.02		984.014		978.145					
10	Pressure drop, Total/Allowed (kPa) 48.042			105.000		11.738		15.000					
11	Velocity, Mid/Max allow (m/s) 0.60					9.43							
12	Mole fraction inert (-)					0.0000							
13	Average film coef. (W/m2-K) 8396.34					7264.35							
14	Heat transfer safety factor (-)			1.000		1.000							
15	Fouling resistance (m2-K/W) 0.000180					0.000350							
16	Overall Performance Data												
17	Overall coef., Req'd/Clean/Actual (W/m2-K) 581.08 /			3066.42 /		1080.08							
18	Heat duty, Calculated/Specified (kW) 38155. /			37608.									
19	Effective overall temperature difference (Deg C) 34.8												
20	EMTD = (MTD) * (DELTA) * (F/G/H) (Deg C) 35.25 * 0.9877 * 1.0000												
21													
22													
23	See Runtime Messages Report for												
24	warnings.												
25													
26	Exchanger Fluid Volumes												
27	Approximate shellside (L) 5464.3												
28	Approximate tubeside (L) 6224.3												
29	Shell Construction Information												
30	TEMA shell type AEL			Shell ID (mm) 1100.00									
31	Shells Series 1 Parallel 2			Total area (m2) 1883.47									
32	Passes Shell 1 Tube 1			Eff. area (m2/shell) 929.377									
33	Shell orientation angle (deg) 1.00												
34	Impingement present Rectangular plate			Imp. length/width (mm) 400 / 400									
35	Pairs seal strips 0			Passlane seal rods (mm) 0.000 No. 0									
36	Shell expansion joint No			Rear head support plate No									
37	Weight estimation Wet/Dry/Bundle 46233.2 / 34552.7 / 15729.5 (kg/shell)												
38													
39	Baffle Information												
40	Type Perpend. Single-Seg.			Baffle cut (% dia) 25.00									
41	Crosspasses/shellpass 21			No. (Pct Area) (mm) to C.L									
42	Central spacing (mm) 530.000			1 21.86 275.000									
43	Inlet spacing (mm) 980.939			2 0.00 0.000									
44	Outlet spacing (mm) 980.939												
45	Baffle thickness (mm) 12.700												
46													
47													
48	Tube Information												
49	Tube type Plain			Tubecount per shell 968									
50	Overall length (mm) 12192.			Pct tubes removed (both) 3.72									
51	Effective length (mm) 12032.			Outside diameter (mm) 25.400									
52	Total tubesheet (mm) 160.000			Wall thickness (mm) 2.110									
53	Area ratio (out/in) 1.1992			Pitch (mm) 31.7500 Ratio 1.2500									
54	Tube metal Carbon steel			Tube pattern (deg) 30									
								Shellside Heat Transfer Corrections					
								Total	Beta	Gamma	End	Fin	
								0.985	0.919	1.072	0.956	1.000	
								Pressure Drops (Percent of Total)					
								Cross	Window	Ends	Nozzle	Shell	Tube
								54.32	29.20	5.36	Inlet	5.09	27.64
								MOMENTUM		0.00	Outlet	6.03	27.49
								Two-Phase Parameters					
								Method	Inlet	Center	Outlet	Mix F	
								RPM	Ann-Mist	Shear	Transition	0.3431	
								H. T. Parameters					
								Shell			Tube		
								Overall wall correction 1.010					
								Midpoint	Prandtl no.	1.36			
								Midpoint	Reynolds no.	64516	20968		
								Bundle inlet	Reynolds no.	28064	96888		
								Bundle outlet	Reynolds no.	42824	11618		
								Fouling layer (mm)					
								Thermal Resistance					
								Shell	Tube	Fouling	Metal	Over Des	
								12.86	17.83	64.78	4.53	85.88	
								Total fouling resistance 5.993e-4					
								Differential resistance 7.951e-4					
								Shell Nozzles					
								Inlet at channel end-No			Inlet	Outlet	Outlet
								Number at each position			1	1	0
								Diameter			(mm) 295.301	295.301	
								Velocity			(m/s) 1.41	1.47	
								Pressure drop			(kPa) 2.447	2.899	
								Height under nozzle			(mm) 75.000	42.666	
								Nozzle R-V-SQ			(kg/m-s2) 1916.26	1996.90	
								Shell ent.			(kg/m-s2) 2481.69	4860.53	
								Tube Nozzle					
								Diameter			(mm) 380.400	295.301	
								Velocity			(m/s) 34.53	32.53	
								Pressure drop			(kPa) 3.244	3.227	
								Nozzle R-V-SQ			(kg/m-s2) 5897.35	9219.41	
								Annular Distributor					
								Length			(mm)	Inlet	Outlet
								Height			(mm)		
								Slot area			(mm2)		
								Diametral Clearances (mm)					
								Baffle-to-shell			Bundle-to-shell	Tube-to-baffle	
								6.3500			25.4000	0.3969	

