



**CHRISTINA LAKE REGIONAL PROJECT
Phase 3A EPC for Central Plant Facilities**



SLI Project No. 511036




SNC-LAVALIN

Vendor's drawing review for conformity with specifications and design drawing.

This review does not relieve the vendor of his responsibility for errors in design and detailing as detailed in his contract.

- A1 Not suitable to initiate fabrication. modify as noted, resubmit for review
- B1 Suitable to initiate fabrication as noted. modify as noted, resubmit for review
- C1 Suitable to fabricate to completion as noted. submit final documents including as-builts as required
- D1 Suitable to fabricate to completion. submit final documents including as-built documents as required
- E1 Not suitable as final documents as noted. modify as noted and resubmit.
- F1 Suitable as final documents. no further resubmittal required (unless revised by vendor)

Vendor: Ecodyne Limited (Canada) - 12123		No.: 32125-A-2051-01	Rev: D	Date Rec'd 2013-08-22
Doc. Title: J00.01 - CROSS SECTION AFTER FILTER - Tag:3A-F-208A/B/C/D/E/F/G				
Client Code:		Project: MEG Phase 3A EPC		
Reviewed by: <i>C. Simons</i>		Document No		Submittal
Date: <i>10 SEP 13</i>		P-5675-02-0033		03



NOTE:

SUBFILL SUPPORT BASE IS AS FOLLOWS:

LAYER	SIEVE SIZE	DEPTH (cm)	VOL (m³)
#1(BOTTOM)	1 5/8"X13/16"	15	1.85
#2	13/16"X9/16"	10	1.25
#3	9/16"X5/16"	10	1.25
#4	5/16"X3/16"	15	1.85
#5	3/16"X3/32"	15	1.85

TITLE
 CROSS SECTION
 AFTER FILTER
 TAG 3A-F-208 A-G
 ⚠

⚠ MEG ENERGY CORP.
 CALGARY, ALBERTA
 CHRISTINA REGIONAL PROJ.
 PHASE 3A- CPF
 ENG.: SNC- LAVALIN
 P.O.: P-5675-02

D	2013AUG15	REVISED AS NOTED	AV	SCALE	N.T.S.
C	2013JUL30	REVISED AS NOTED	CS	AV	BY DATE
B	2013JAN16	REV'D AS NOTED	IA	FH	DRN. IA 2012DEC10
A	2012DEC13	FIRST ISSUE	IA	FH	CH'D. FH 2012DEC13
REV DATE	REMARKS		BY	CHKD	APPR. AV 2012DEC13

ECODYNE Limited
 A Marmon Water / Berkshire Hathaway Company
 DWG. NO. 32125-A-2051-01 REV D